



All About Alkalinity

IT PLAYS A CRUCIAL ROLE IN WATER BALANCE FOR POOLS AND SPAS

WHAT IS TOTAL ALKALINITY?

Total alkalinity is the amount of bicarbonate, plus the much smaller amount of carbonate, plus (in stabilized pools) the amount of cyanurate ions. It is a measure of the pH buffering capacity of water; that is, the ability of water to resist a pH change. Alkalinity is generally expressed in terms of the equivalent concentration of calcium carbonate in ppm.

By the APSP Recreational Water Quality Committee (RWQC)

Balancing pool and spa water is perhaps the fundamental job of the service pro, and total alkalinity is a key parameter in that process.

The proper total alkalinity level in pool or spa water provides buffering so pH does not swing in and out of the proper range in response to sanitizer addition, bather load or other factors. With too little alkalinity, there will not be enough buffering and the pH may quickly drift out of the proper range. At excessively high bicarbonate/carbonate alkalinity, there will be a tendency for the pH of the water to drift upward, due to the rapid escape of carbon dioxide from the water into the air.

In addition to these effects on pH, the portion of the alkalinity coming from carbonate and bicarbonate, called carbonate alkalinity, also affects calcium

carbonate saturation. The maintenance of calcium carbonate concentration within the recommended range reduces the tendency of pool water to scale or degrade pool surfaces.

When total alkalinity is properly adjusted, optimum buffering results are achieved; pH, swimmer comfort, sanitizer efficacy, water balance and clarity are more easily maintained.

How To Adjust

Total alkalinity should be corrected before adjusting pH or sanitizer levels. (See notes below regarding "Adjusting for the Effect of Cyanuric Acid on Total Alkalinity.")

To reduce total alkalinity, acid is added to the water. Approximately 2.1 pounds of sodium bisulfate

(94 percent) or 1.6 pints of muriatic acid (31 percent) will reduce the total alkalinity of 10,000 gallons of water by 10 ppm.

To increase total alkalinity, use sodium bicarbonate. Approximately 1.5 pounds of sodium bicarbonate (100 percent) will raise the total alkalinity of 10,000 gallons of water by 10 ppm.

Adjusting for Effect of Cyanuric Acid on Total Alkalinity:

Dichlor and trichlor sanitizers release cyanuric acid, which serves to stabilize the chlorine sanitizer. Cyanuric acid stabilizer may be added separately as well. The cyanurate system is a weak buffer and will contribute to the total alkalinity measurement.

To determine the carbonate alkalinity in a stabilized pool or spa:

1. Measure the pH
2. Measure total alkalinity (TA)
3. Measure cyanuric acid concentration (CA). If the CA is 90ppm or greater, it may be necessary to dilute the pool water sample with tap water to get an accurate reading.
4. Note the Cyanuric Acid Correction Factor in Table 1, based on the pH of the water.

5. Adjust the CA and subtract this result from the total alkalinity for the actual or corrected TA.

6. Formula : Measured TA – (CA x Cyanuric Acid Correction Factor) = Carbonate Alkalinity

pH	Correction Factor
7.0	0.23
7.2	0.27
7.4	0.31
7.6	0.33
7.8	0.35
8.0	0.36

Example: pH is 7.4. Total Alkalinity measurement (Measured TA) is 110 ppm. Cyanuric Acid level is 100 ppm.

Cyanuric Acid Correction factor at pH 7.4 is 0.31. (See table above)

Using the formula:

$110 \text{ ppm} - (100 \times 0.31) = 110 - 31 = 79$ ppm carbonate alkalinity

THE RIGHT AMOUNT OF TA

TOTAL ALKALINITY should be maintained between a minimum 60 and a maximum of 180 ppm as CaCO₃ (calcium carbonate). Ideally, total alkalinity should be maintained between 80 and 100 ppm as CaCO₃ where electrolytic chlorine generators, calcium hypochlorite, lithium hypochlorite and sodium hypochlorite are

SALTWATER PROBLEMS?

Zinc Sacrificial Anodes



PART# 104-D SPIGOT

Fits into any standard 2" Tee



PART# 104-C

1.5" & 2" Retrofit



PART# 104-D

2" Slip x Slip New Install

HELPS PREVENT

- Plaster Discoloration
- Metal Erosion
- Pool Light Damage & erosion
- Heater Damage

Five years of field testing by a corrosion engineer, guarantees the best protection in the industry.



POOL TOOL CO.
805.644.2333
www.pooltoolco.com

Call for free catalog!

Available at your local distributor

AQUA

PRINT | DIGITAL | SOCIAL
aquamagazine.com/subscribe



NEVER MISS AN ISSUE |
RENEW YOUR COMPLIMENTARY SUBSCRIPTION

used, because these sanitizers cause the pH to rise. The ideal range where sodium dichlor, trichlor, chlorine gas and bromine compounds are used is between 100 and 120 ppm as CaCO₃, because these sanitizers will cause the pH to drift downwards. Certain systems such as PHMB are relatively unaffected by and do not impact total alkalinity.

APSP Recreational Water Quality Committee

RWQC Chairman
JOSEPH LAURINO, PH.D.
Periodic Products

JAMES EGAN, PH.D.
LaMotte Company

GREGORY GARRETT
Applied Materials Technologies, Inc.

KENNETH GREGORY
Pentair Water Quality Systems

BRETT GEREAU
Purified Pool Water

CHRIS KAREIS, PH.D.
Axiall, A Westlake Company

JODY O'GRADY
Taylor Technologies, Inc.

DAVID OXLEY
Belleair Pool Service & Supply

SHAJEE SIDDIQUI
Zodiac Pool Systems, Inc.

KIM SKINNER
Pool Chlor

ROY VORE, PH.D.
Bio-Lab, Inc.

JOHN WEBER
Lonza

REFERENCES

1. The Association of Pool and Spa Professionals "APSP Service Tech Manual, Basic Pool & Spa Technology," The Association of Pool and Spa Professionals Third Edition., Alexandria, Virginia
2. The Association of Pool and Spa Professionals "Chemical Operational Parameters." The Association of Pool and Spa Professionals, Alexandria, Virginia.

3. Wojtowicz, J.A. "Treatment of Swimming Pools, Spas, and Hot Tubs". Kirk -Othmer Encyclopedia of Chemical Technology, Fourth Edition, Vol. 25, New York, NY. John Wiley and Sons, Inc., pp 569-594, 1998
4. Wojtowicz, J.A. "The Carbonate System in Swimming Pool Water" Journal of the Swimming Pool and Spa Industry, 3(1)(2001):54-59

Western Pool & Spa Show
The place to be...

39 Years
1978-2017

EXHIBITORS:

Promo #1
Any Exhibitor not Previously a Member
> Join CPSA Between Now and Feb. 26, 2017
And Receive 2 FREE Email Blasts to Our Entire Attendee List.

Promo #2
Any NEW Exhibitor to the Western Pool & Spa Show
Sign-Up Now and Receive
50% Off Carpet in Your Booth

ATTENDEES:

- 40+ New Seminar Classes
- Classes in Spanish (All 3 Days)
- WIN A DODGE TRUCK
Saturday Drawing (Must be Eligible to Win)
Hourly Prize Drawings All 3 Days
- Make Sure to Register Early online for Your FREE Floor Access Badge
- CPO® Certification Class
March 9-10, 2017 at the Renaissance Hotel
SPECIAL WESTERN SHOW PRICE
- APSP Certified Construction and Hot Tub classes.

39th Annual Western Pool & Spa Show
March 9-11, 2017
Long Beach Convention Center
300 E. Ocean Blvd., Long Beach CA 90802

Email: exhibitsales@westernshow.com
financialoffice@westernshow.com
Call: 800-746-9772

westernshow.com